



TYPE APPROVAL CERTIFICATE

N. ELE369421CS011

This is to certify that the product below is found to be in compliance with the applicable requirements of the RINA Type Approval system.

| | |
|--------------------------|--|
| Description | Fire detection and fire alarm system |
| Type | CAL 10252 |
| Applicant | SAN GIORGIO S.E.I.N. Srl Via A. Pedullà 59 16165 Genova Italy |
| Manufacturer | SAN GIORGIO S.E.I.N. Srl Via A. Pedullà 59 16165 Genova Italy |
| Testing Standards | Rules for the Classification of Ships – Part C – Machinery Systems and fire protection – Ch. 3, Sect. 6, Tab. 1 |

Issued in **Genova** on **September 24, 2021**

This certificate is valid until **September 24, 2026**

RINA Services S.p.A.

Luigi Benedetti



TYPE APPROVAL CERTIFICATE

N. ELE369421CS011

Fire detection and fire alarm system type CAL 10252

Main features:

8 LED red color for Zone alarm (max 4 fire detectors for each loop)

1 LED yellow color for Failure alarms:

- power supply failure,
- insulation failure,
- electronic failure,
- loop short circuit and loop disconnection.

Fire alarm output (two minutes delay) according to SOLAS Requirements

Main power supply: 24Vdc

Emergency power supply: 24Vdc

Reference documents:

Technical Manual / User's instruction: M991119 rev.6

Test reports:

Proteco report n. 99 B233 M (11/23/1999)

Teslab report n. 05B169 E (13/12/2005)

RINA report n. 98DGTO1274 (03/05/99)

RINA report n. 99CS303TO Mod. 81 (03/03/2000)

ACS Electronic report n. RPT12110005 (13/09/21)